

APPENDIX C
MANUFACTURER'S/INSTALLING CONTRACTOR'S REPORT
FOR ASME CSD-1

UNIT MANUFACTURER

Name Cleveland Range, LLC
 Address 1333 East 179th Street
 City Cleveland State Ohio Zip 44110

UNIT IDENTIFICATION (Boiler)

Manufacturer's Model # 24CGM200 Year Built 2005
 ASME # 12,250 Nat. Bd. # 106843 Serial No. 92260-05G-01
 UL # NONE CSA # 156602-1289047
 Jurisdiction _____

STEAM

Max. W.P. 15 psig
 Min. Safety Valve Cap. 266 PPH

BOILER UNIT DESCRIPTION (TYPE) Steam
 BOILER UNIT CAPACITY (OUTPUT) 180 PPH

Burner - Manufacturer Robertshaw
 CSA # None - Certified under ANSI Z83.11 as part of Cleveland Range, LLC.
Model 24CGM200 Report No. 156602-1289047.

FUELS (as shipped) Natural gas

INSTALLATION LOCATION (if known)

Customer Name _____
 Address _____
 City _____ State _____ Zip _____
 Telephone _____ FAX _____

Control/Device	Manufacturer	Model or Catalog #	Operational Test Performed, Date
OPERATING CONTROLS			
Low-Water Fuel Cutoff CW-120 (a)	National Controls, Corp	LCR-NS210-120D	
Steam Pressure CW-310 (b)	Honeywell	PA404A	
SAFETY CONTROLS			
Low-Water Fuel Cutoff CW-120 (a)	Transamerica Delaval National Controls, Corp	LS 19700 LCR-NS210-120D	
High Steam Pressure Limit CW-310 (c)	Honeywell	PA404A	

<u>SAFETY CONTROLS</u> (continued)			
Control/Device	Manufacturer	Model #	Operational Test Performed, Date
Fuel Safety Shutoff Valve, Main	Honeywell	VR8305	
Flame Safeguard (primary) CF-310, CF-320	Honeywell	S87B	
Flame Detector CF-310, CF-320	Honeywell	Q347	

SAFETY OR SAFETY RELIEF VALVE(S)
CW-510

OPERATING TEST
PERFORMED, DATE _____

Manufacturer Conbraco Ind. Inc.
Model 13-211
Size 3/4"
Capacity 475 PPH

Representing Equipment Manufacturer, Name _____

Signature _____

Date _____

Representing Installing Contractor, Name _____

Signature _____

Date _____